

IEC

IECEE



TM

Ref. Certif. No.

CN73703

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

ACB

Name and address of the applicant

ZHEJIANG TENGGEN ELECTRIC CO.,LTD.
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang
Province, P.R.China

Name and address of the manufacturer

ZHEJIANG TENGGEN ELECTRIC CO.,LTD.
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang
Province, P.R.China

Name and address of the factory

*Note: When more than one factory, please report on page 2*Yueqing Economic Development Branch of Zhejiang Tengen
Electric Co.,Ltd.
No.288 Central Avenue, Development Zone, Yueqing City,
Zhejiang Province, P.R.China

Ratings and principal characteristics

See the Appendix

Trademark (if any)

TENGEN

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

TGW5-4000HUW,TGW5F-4000HUW,TGW5-4000HUS,TGW
5F-4000HUS;Additional information (if necessary may also be
reported on page 2)A sample of the product was tested and found
to be in conformity withIEC 60947-2:2016/AMD1:2019;IEC 60947-2:2016(5th
Edition);IEC 60947-1:2007, IEC 60947-1:2007/AMD1:2010,
IEC 60947-1:2007/AMD2:2014As shown in the Test Report Ref. No. which
forms part of this Certificate

(2025)MJDQ-CB1425

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Oct.11,2025

Signature:

谢肇煦

Xie ZhaoXu



TGW5-4000HUW,TGW5F-4000HUW,TGW5-4000HUS,TGW5F-4000HUS
Uimp:12kV (TGW5-4000HUW,TGW5F-4000HUW), 18kV (TGW5-4000HUS,TGW5F-4000HUS);
Ui: 1250V (TGW5-4000HUW,TGW5F-4000HUW), 1800V (TGW5-4000HUS,TGW5F-4000HUS);
Ue:AC800V,1000V,1140V;
In:1600A,2000A,2500A,2900A,3200A,3600A,4000A;
Type of over-current release: Electronic;
TGW5-4000HUW,TGW5F-4000HUW:
Ics:50kA,Icu:50kA,Icw:50kA/1s;
TGW5-4000HUS,TGW5F-4000HUS:
AC800V: Ics:75kA,Icu:75kA,Icw:75kA/1s;
AC1000V,1140V: Ics:60kA,Icu:60kA,Icw:60kA/1s;
Selectivity category:B;3P,4P; Suitable for isolation;50/60Hz;
Matching auxiliary contact:4NO4NC, 5NO5NC, 6NO6NC, 7NO7NC, 8NO8NC;Ith:10A,
Ui:400V;AC-15:AC400V/2A;DC-13:DC250V/0.3A;
Electronic accessory complying with annex N:
Undervoltage release:AC220/230/240V,AC380/400/415V,DC24V;
Shunt release:AC380/400/415V,AC220/230/240/DC220V,DC110V
Closing coil: AC380/400/415V,AC220/230/240/DC220V,DC110V

Page 1 of 1

Additional information (if necessary)

Date:

Oct.11,2025

Signature:


Xie ZhaoXu